

POWER SYSTEM OPERATION CORPORATION LIMITED.



SOUTHERN REGIONAL LOAD DESPATCH CENTRE

GENERATING UNITS OUTAGE STATUS IN SOUTHERN REGION

AS ON DATE

26-Dec-15

TIME 06:00 HRS

1 A. Generating Units Revived during Last 30 HRS (00:00 HRS of 25-Dec-15 to 06:00 HRS of 26-Dec-15)

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		REVIVAL		REASON OF OUTAGE
					DATE	TIME	DATE	TIME	
CENTRAL SECTOR									
1	NTPL	NTPL	UNIT 2	500 MW	24-DEC-2015	20:03:00	25-DEC-2015	02:37:00	ELECTRO HYDRO GOVERNOR SYSTEM TRIP
2									
3									
4									
5									
STATE SECTOR									
1	BELLARY TPS	KPCL	UNIT 1	500 MW	23-DEC-2015	16:53:00	26-DEC-2015	01:30:00	BOILER TUBE LEAKAGE
2	METTUR TPS	TNEB	UNIT 4	210 MW	24-DEC-2015	00:50:00	26-DEC-2015	03:38:00	BOILER TUBE LEAKAGE
3	NEYVELI I	TNEB	UNIT 9	100 MW	24-DEC-2015	09:55:00	25-DEC-2015	08:10:00	BOILER TUBE LEAKAGE
4									
5									

1 B. Generating Units Under Planned Outage (Status at 06:00 HRS of 26-Dec-15)

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
CENTRAL SECTOR								
1	KUDANKULAM NPS	KKNPP	UNIT 1	1000 MW	24-JUN-2015	11:30:00	20-JAN-2015	ANNUAL MAINTENANCE
2	MADRAS APS	MAPS	UNIT 2	220 MW	30-NOV-2015	23:12:00	10-JAN-2016	BI ANNUAL MAINTENANCE
3								
4								
5								
STATE SECTOR								
1	BELLARY TPS	KPCL	UNIT 2	500 MW	11-DEC-2015	00:32:00	11-JAN-2016	ANNUAL MAINTENANCE
2	NEYVELI I	TNEB	UNIT 5	50 MW	21-DEC-2015	08:40:00	21-JAN-2016	ANNUAL MAINTENANCE
3	SIMHADRI TPS	NTPC_SIMH	UNIT 2	500 MW	15-NOV-2015	15:01:00	29-DEC-2015	ANNUAL MAINTENANCE
4	VIJAYAWADA TPS	APGENCO	UNIT 7	500 MW	10-NOV-2015	13:16:00	29-DEC-2015	ANNUAL MAINTENANCE
5								

1 C. Generating Units Under Forced Outage (Status at 06:00 HRS of 26-Dec-15)

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
CENTRAL SECTOR								
1	NEYVELI TS II EXP	NLC	UNIT 2	250 MW	25-NOV-2015	23:12:00	28-DEC-2015	BOILER PROTECTION ACTED
2	RAMAGUNDAM STPS	NTPC_RSTPS	UNIT 7	500 MW	25-DEC-2015	01:14:00	26-DEC-2015	BOILER TUBE LEAKAGE
3	SIMHADRI TPS	NTPC_SIMH	UNIT 4	500 MW	25-DEC-2015	14:19:00	28-DEC-2015	TO ATTEND PAPH
4	VALLUR	NTECL	UNIT 3	500 MW	30-NOV-2015	14:07:00	29-DEC-2015	GENERATOR PROTECTION ACTED
5								
STATE SECTOR								
1	ENNORE TPS	TNEB	UNIT 1	60 MW	13-NOV-2015	20:44:00	28-DEC-2015	H/T DUE TO WET COAL
2	ENNORE TPS	TNEB	UNIT 2	60 MW	26-APR-2014	11:34:00	29-DEC-2015	CONDENSER TUBE LEAKAGE
3	ENNORE TPS	TNEB	UNIT 3	110 MW	09-JUN-2015	23:27:00	29-DEC-2015	GEN.PROTECTION OPERATED
4	LANCO ST2	LANCO_LAN	UNIT 1	233 MW	18-OCT-2015	07:00:00	29-DEC-2015	H/T DUE TO NO GAS ALLOCATION
5	LANCO ST2	LANCO_LAN	UNIT 2	133 MW	18-OCT-2015	07:00:00	29-DEC-2015	H/T DUE TO NO GAS ALLOCATION
6	LANCO ST3B	LANCO_LAN	UNIT 1	233 MW	05-SEP-2015	12:31:00	29-DEC-2015	H/T AFTER COMPLETION OF TESTING WORKS
7	LANCO ST3B	LANCO_LAN	UNIT 2	133 MW	05-SEP-2015	12:31:00	29-DEC-2015	H/T AFTER COMPLETION OF TESTING WORKS
8	MEENAKSHI	MEPL	UNIT 1	150 MW	19-DEC-2015	01:10:00	01-JAN-2016	TURBINE TRIPPED
9	NEYVELI I	TNEB	UNIT 6	50 MW	26-NOV-2015	08:05:00	29-DEC-2015	BOILER TUBE LEAKAGE
10	NORTH CHENNAI TPS	TNEB	UNIT 2	210 MW	18-DEC-2015	01:25:00	02-JAN-2016	PA FAN PROBLEM
11	SDS TPS	APGENCO	UNIT 2	800 MW	23-NOV-2015	18:14:00	29-DEC-2015	BOILER MAINTENANCE WORKS