

**POWER SYSTEM OPERATION CORPORATION LIMITED.**



**SOUTHERN REGIONAL LOAD DESPATCH CENTRE**

**GENERATING UNITS OUTAGE STATUS IN SOUTHERN REGION**

**AS ON DATE 15-May-15 TIME 06:00 HRS**

**1 A. Generating Units Revived during Last 30 HRS ( 00:00 HRS of 14-May-15 to 06:00 HRS of 15-May-15)**

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		REVIVAL		REASON OF OUTAGE
					DATE	TIME	DATE	TIME	
<b>CENTRAL SECTOR</b>									
1	KUDANKULAM NPS	KKNPP	UNIT 1	1000 MW	09-MAY-2015	18:38:00	14-MAY-2015	04:47:00	REACTOR TRIP DUE TO TRANSIENT IN STEAM GENERATOR LEVEL CONTROL
2									
3									
4									
5									
<b>STATE SECTOR</b>									
1	RAICHUR TPS	KPCL	UNIT 5	210 MW	12-MAY-2015	23:10:00	14-MAY-2015	09:33:00	B T L
2	RAICHUR TPS	KPCL	UNIT 8	250 MW	14-MAY-2015	08:06:00	14-MAY-2015	23:25:00	BOILER TRIPPED
3									
4									
5									

**1 B. Generating Units Under Planned Outage ( Status at 06:00 HRS of 15-May-15)**

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
<b>CENTRAL SECTOR</b>								
1								
2								
3								
4								
5								
<b>STATE SECTOR</b>								
1								
2								
3								
4								
5								

**1 C. Generating Units Under Forced Outage ( Status at 06:00 HRS of 15-May-15)**

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
<b>CENTRAL SECTOR</b>								
1	NEYVELI TS II EXP	NLC	UNIT 1	250 MW	13-MAR-2015	17:21:00	14-MAY-2015	BOILER SIDE PROBLEM
2	RAMAGUNDAM STPS	NTPC_RSTPS	UNIT 6	500 MW	14-MAY-2015	08:49:00		BOILER TUBE LEAKAGE
3	VALLUR	NTECL	UNIT 1	500 MW	13-MAY-2015	14:25:00	15-MAY-2015	BOILER TUBE LEAKAGE
4	VALLUR	NTECL	UNIT 2	500 MW	14-MAY-2015	10:17:00		BOILER TUBE LEAKAGE
5								
<b>STATE SECTOR</b>								
1	ENNORE TPS	TNEB	UNIT 2	60 MW	26-APR-2014	11:34:00	13-MAY-2015	AXIAL SHIFT HIGH
2	NTPL	NTPL	UNIT 1	500 MW	13-MAY-2015	00:22:00	14-MAY-2015	SLACK CONVEYOR PROBLEM
3	SDS TPS	APGENCO	UNIT 1	800 MW	04-FEB-2015	06:50:00	01-JUN-2015	H/T DUE TO LESS COAL SUPPLY
4	SDS TPS	APGENCO	UNIT 2	800 MW	07-MAY-2015	10:18:00	13-MAY-2015	TRIPPED ON BOILER ASH HOOPER PROBLEM
5	SIMHAPURI	SEPL	UNIT 2	150 MW	13-MAY-2015	10:49:00		REFRACTORY DAMAGE
6	UPCL	LANCO_UPCL	UNIT 1	600 MW	14-MAY-2015	08:34:00		MS DRAIN LEAKAGE