

POWER SYSTEM OPERATION CORPORATION LIMITED.



SOUTHERN REGIONAL LOAD DESPATCH CENTRE

GENERATING UNITS OUTAGE STATUS IN SOUTHERN REGION

AS ON DATE

04-Nov-15

TIME 06:00 HRS

1 A. Generating Units Revived during Last 30 HRS (00:00 HRS of 03-Nov-15 to 06:00 HRS of 04-Nov-15)

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		REVIVAL		REASON OF OUTAGE
					DATE	TIME	DATE	TIME	
CENTRAL SECTOR									
1	NTPL	NTPL	UNIT 2	500 MW	03-NOV-2015	11:21:00	03-NOV-2015	21:33:00	TRIPPED ON GENERATOR O/V
2	RAMAGUNDAM STPS	NTPC_RSTPS	UNIT 6	500 MW	02-NOV-2015	11:58:00	03-NOV-2015	13:16:00	B T L
3	VALLUR	NTECL	UNIT 1	500 MW	01-NOV-2015	19:14:00	03-NOV-2015	14:29:00	BOILER TUBE LEAKAGE
4	NEYVELI TS I EXP	NLC	UNIT 1	210 MW	12-OCT-2015	12:40:00	03-NOV-2015	02:12:00	ANNUAL MAINTENANCE
5	NEYVELI TS II EXP	NLC	UNIT 1	250 MW	15-SEP-2015	11:55:00	03-NOV-2015	02:12:00	BOILER TUBE LEAKAGE
STATE SECTOR									
1	COSTEL ENERGEN	COSTAL	UNIT 1	600 MW	02-NOV-2015	12:00:00	03-NOV-2015	04:13:00	NO REQUISITION FROM TN
2	TPCIL	TPCIL	UNIT 2	660 MW	28-OCT-2015	01:44:00	03-NOV-2015	05:59:00	FOR ATTENDING THE MAIN STEAM DRAIN LINE LEAKAGE.
3									
4									
5									

1 B. Generating Units Under Planned Outage (Status at 06:00 HRS of 04-Nov-15)

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
CENTRAL SECTOR								
1	KUDANKULAM NPS	KKNPP	UNIT 1	1000 MW	24-JUN-2015	11:30:00	11-NOV-2015	ANNUAL MAINTENANCE
2	NEYVELI II	NLC	UNIT 2	210 MW	18-OCT-2015	00:04:00	18-NOV-2015	ANNUAL MAINTENANCE
3	NEYVELI II	NLC	UNIT 6	210 MW	25-OCT-2015	23:30:00	30-NOV-2015	ANNUAL MAINTENANCE
4								
5								
STATE SECTOR								
1	KOTHAGUDAM TPS	TGGENCO	UNIT 3	60 MW	28-OCT-2015	08:35:00	20-NOV-2015	ANNUAL MAINTENANCE
2	KOTHAGUDAM TPS	TGGENCO	UNIT 5	120 MW	03-NOV-2015	09:25:00	30-NOV-2015	ANNUAL MAINTENANCE
3	NEYVELI I	TNEB	UNIT 7	100 MW	05-OCT-2015	11:35:00	10-NOV-2015	ANNUAL MAINTENANCE
4	VIJAYAWADA TPS	APGENCO	UNIT 3	210 MW	28-OCT-2015	00:06:00	20-NOV-2015	ANNUAL MAINTENANCE
5								

1 C. Generating Units Under Forced Outage (Status at 06:00 HRS of 04-Nov-15)

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
CENTRAL SECTOR								
1	NTPL	NTPL	UNIT 1	500 MW	02-NOV-2015	22:57:00	06-NOV-2015	H/T DUE TO TURBINE OIL LEAKAGE
2								
3								
4								
5								
STATE SECTOR								
1	BELLARY TPS	KPCL	UNIT 1	500 MW	03-NOV-2015	09:25:00	06-NOV-2015	TRIPPED ON FURNACE PRESSURE LOW
2	ENNORE TPS	TNEB	UNIT 2	60 MW	26-APR-2014	11:34:00	10-NOV-2015	CONDENSER TUBE LEAKAGE
3	ENNORE TPS	TNEB	UNIT 3	110 MW	09-JUN-2015	23:27:00	11-NOV-2015	GEN.PROTECTION OPERATED
4	LANCO ST2	LANCO_LAN	UNIT 1	233 MW	18-OCT-2015	07:00:00	05-NOV-2015	H/T DUE TO NO GAS ALLOCATION
5	LANCO ST2	LANCO_LAN	UNIT 2	133 MW	18-OCT-2015	07:00:00	08-NOV-2015	H/T DUE TO NO GAS ALLOCATION
6	LANCO ST3B	LANCO_LAN	UNIT 1	233 MW	05-SEP-2015	12:31:00	11-NOV-2015	H/T AFTER COMPLETION OF TESTING WORKS
7	LANCO ST3B	LANCO_LAN	UNIT 2	133 MW	05-SEP-2015	12:31:00	11-NOV-2015	H/T AFTER COMPLETION OF TESTING WORKS
8	RAICHUR TPS	KPCL	UNIT 3	210 MW	23-MAY-2015	15:58:00	15-NOV-2015	GT FLASHOVER
9	RAICHUR TPS	KPCL	UNIT 6	210 MW	28-OCT-2015	01:02:00	07-NOV-2015	ANNUAL OVERHAULING