

**POWER SYSTEM OPERATION CORPORATION LIMITED.**



**SOUTHERN REGIONAL LOAD DESPATCH CENTRE**

**GENERATING UNITS OUTAGE STATUS IN SOUTHERN REGION**

**AS ON DATE**

**12-Nov-15**

**TIME 06:00 HRS**

**1 A. Generating Units Revived during Last 30 HRS ( 00:00 HRS of 11-Nov-15 to 06:00 HRS of 12-Nov-15)**

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		REVIVAL		REASON OF OUTAGE
					DATE	TIME	DATE	TIME	
<b>CENTRAL SECTOR</b>									
1	NTPL	NTPL	UNIT 2	500 MW	11-NOV-2015	05:28:00	11-NOV-2015	12:02:00	MASTER FUEL TRIP
2	VALLUR	NTECL	UNIT 1	500 MW	09-NOV-2015	20:43:00	11-NOV-2015	13:08:00	H/T DUE TO COAL SHORTAGE
3									
4									
5									
<b>STATE SECTOR</b>									
1	COSTEL ENERGEN	COSTAL	UNIT 1	600 MW	08-NOV-2015	0	11-NOV-2015	17:05:00	NO SCHEDULE
2	MEENAKSHI	MEPL	UNIT 2	150 MW	10-NOV-2015	17:30:00	11-NOV-2015	04:38:00	TRIPPED ON COAL JAMMING
3	RAICHUR TPS	KPCL	UNIT 4	210 MW	09-NOV-2015	10:23:00	11-NOV-2015	22:15:00	BOILER TUBE LEAKAGE
4	RAICHUR TPS	KPCL	UNIT 4	210 MW	12-NOV-2015	00:30:00	12-NOV-2015	02:44:00	BUSBAR PROTECTION OPERATED
5	RAICHUR TPS	KPCL	UNIT 7	210 MW	07-NOV-2015	15:20:00	12-NOV-2015	02:44:00	AUX. SUPPLY FAILURE
6	TUTUCORIN TPS	TNEB	UNIT 4	210 MW	08-NOV-2015	19:40:00	11-NOV-2015	11:56:00	H/T DUE TO LOW DEMAND

**1 B. Generating Units Under Planned Outage ( Status at 06:00 HRS of 12-Nov-15)**

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
<b>CENTRAL SECTOR</b>								
1	KUDANKULAM NPS	KKNPP	UNIT 1	1000 MW	24-JUN-2015	11:30:00	19-NOV-2015	ANNUAL MAINTENANCE
2	NEYVELI II	NLC	UNIT 2	210 MW	18-OCT-2015	00:04:00	18-NOV-2015	ANNUAL MAINTENANCE
3	NEYVELI II	NLC	UNIT 6	210 MW	25-OCT-2015	23:30:00	30-NOV-2015	ANNUAL MAINTENANCE
4	NEYVELI TS I EXP	NLC	UNIT 2	210 MW	05-NOV-2015	08:54:00		ANNUAL MAINTENANCE
5								
<b>STATE SECTOR</b>								
1	KOTHAGUDAM TPS	TGGENCO	UNIT 4	60 MW	07-NOV-2015	01:12:00	07-DEC-2015	ANNUAL MAINTENANCE
2	KOTHAGUDAM TPS	TGGENCO	UNIT 5	120 MW	03-NOV-2015	09:25:00	30-NOV-2015	ANNUAL MAINTENANCE
3	NEYVELI I	TNEB	UNIT 7	100 MW	05-OCT-2015	11:35:00	10-NOV-2015	ANNUAL MAINTENANCE
4	VIAJAWADA TPS	APGENCO	UNIT 7	500 MW	10-NOV-2015	13:16:00	10-DEC-2015	ANNUAL MAINTENANCE
5								

**1 C. Generating Units Under Forced Outage ( Status at 06:00 HRS of 12-Nov-15)**

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
<b>CENTRAL SECTOR</b>								
1	KAIGA APS	KGS	UNIT 1	220 MW	09-NOV-2015	23:45:00	14-NOV-2015	TURBINE PROBLEM
2	MADRAS APS	MAPS	UNIT 1	220 MW	09-NOV-2015	09:33:00	14-NOV-2015	DUE TO TRIPPING OF EVACUATION LINES
3	MADRAS APS	MAPS	UNIT 2	220 MW	09-NOV-2015	09:33:00	14-NOV-2015	DUE TO TRIPPING OF EVACUATION LINES
4	NEYVELI II	NLC	UNIT 1	210 MW	09-NOV-2015	18:34:00	10-NOV-2015	BOILER PROTECTION OPERATED
5	NEYVELI II	NLC	UNIT 3	210 MW	08-NOV-2015	13:00:00	10-NOV-2015	WATER WALL PUNCTURE
6	NEYVELI II	NLC	UNIT 5	210 MW	10-NOV-2015	19:10:00		WET LIGNITE
7	NEYVELI II	NLC	UNIT 7	210 MW	10-NOV-2015	18:46:00		H/T ON WET LIGNITE
8	NEYVELI TS II EXP	NLC	UNIT 1	250 MW	09-NOV-2015	13:30:00	10-NOV-2015	BOILER PROTECTION OPERATED
9	NEYVELI TS II EXP	NLC	UNIT 2	250 MW	09-NOV-2015	13:25:00	10-NOV-2015	BOILER PROTECTION OPERATED
10	VALLUR	NTECL	UNIT 3	500 MW	09-NOV-2015	22:49:00	14-NOV-2015	H/T DUE TO COAL SHORTAGE
<b>STATE SECTOR</b>								
1	BELLARY TPS	KPCL	UNIT 1	500 MW	06-NOV-2015	03:54:00	13-NOV-2015	GENERATOR BOTTOM RING HEADER DAMAGED
2	ENNORE TPS	TNEB	UNIT 1	60 MW	05-NOV-2015	05:23:00	12-NOV-2015	GEN.PROTECTION OPERATED
3	ENNORE TPS	TNEB	UNIT 2	60 MW	26-APR-2014	11:34:00	16-NOV-2015	CONDENSER TUBE LEAKAGE
4	ENNORE TPS	TNEB	UNIT 3	110 MW	09-JUN-2015	23:27:00	16-NOV-2015	GEN.PROTECTION OPERATED
5	IL&FS	IL&FS	UNIT 1	600 MW	08-NOV-2015	18:53:00	08-DEC-2015	H/T DUE TO NO SCH.
6	LANCO ST2	LANCO_LAN	UNIT 1	233 MW	18-OCT-2015	07:00:00	14-NOV-2015	H/T DUE TO NO GAS ALLOCATION
7	LANCO ST2	LANCO_LAN	UNIT 2	133 MW	18-OCT-2015	07:00:00	14-NOV-2015	H/T DUE TO NO GAS ALLOCATION
8	LANCO ST3B	LANCO_LAN	UNIT 1	233 MW	05-SEP-2015	12:31:00	14-NOV-2015	H/T AFTER COMPLETION OF TESTING WORKS
9	LANCO ST3B	LANCO_LAN	UNIT 2	133 MW	05-SEP-2015	12:31:00	14-NOV-2015	H/T AFTER COMPLETION OF TESTING WORKS
10	METTUR ST3	TNEB	UNIT 1	600 MW	03-NOV-2015	02:54:00	17-NOV-2015	BOILER TUBE LEAKAGE
11	METTUR TPS	TNEB	UNIT 1	210 MW	09-NOV-2015	10:02:00	14-NOV-2015	H/T DUE TO LOW DEMAND
12	NCTPS ST2	TNEB	UNIT 1	600 MW	08-NOV-2015	14:39:00		LOW DEMAND
13	NCTPS ST2	TNEB	UNIT 2	600 MW	09-NOV-2015	13:01:00	11-NOV-2015	BOILER PROTECTION OPERATED
14	NEYVELI I	TNEB	UNIT 1	50 MW	09-NOV-2015	10:31:00		H/T DUE TO WET COAL
15	NEYVELI I	TNEB	UNIT 2	50 MW	08-NOV-2015	13:40:00		LIGNITE SHORTAGE
16	NEYVELI I	TNEB	UNIT 3	50 MW	09-NOV-2015	07:50:00		H/T DUE TO WET COAL
17	NEYVELI I	TNEB	UNIT 4	50 MW	09-NOV-2015	06:40:00		H/T DUE TO WET COAL
18	NEYVELI I	TNEB	UNIT 5	50 MW	08-NOV-2015	16:36:00		LIGNITE SHORTAGE
19	NEYVELI I	TNEB	UNIT 6	50 MW	08-NOV-2015	15:17:00		LIGNITE SHORTAGE
20	NEYVELI I	TNEB	UNIT 8	100 MW	09-NOV-2015	18:17:00		H/T DUE TO WET COAL
21	NEYVELI I	TNEB	UNIT 9	100 MW	09-NOV-2015	19:56:00		H/T DUE TO WET COAL
22	NORTH CHENNAI TPS	TNEB	UNIT 4	210 MW	08-NOV-2015	0	15-NOV-2015	B T L
23	NORTH CHENNAI TPS	TNEB	UNIT 5	210 MW	09-NOV-2015	13:04:00	14-NOV-2015	DC SUPPLY FAILURE
24	RAICHUR TPS	KPCL	UNIT 5	210 MW	12-NOV-2015	00:30:00	13-NOV-2015	BUSBAR PROTECTION OPERATED
25	RAICHUR TPS	KPCL	UNIT 6	210 MW	28-OCT-2015	01:02:00	13-NOV-2015	ANNUAL OVERHAULING
26	RAICHUR TPS	KPCL	UNIT 8	250 MW	12-NOV-2015	00:30:00	13-NOV-2015	BUSBAR PROTECTION OPERATED
27	TPCIL	TPCIL	UNIT 1	660 MW	10-NOV-2015	04:19:00	14-NOV-2015	DUE TO COOLING WATER LAEKAGE

