

POWER SYSTEM OPERATION CORPORATION LIMITED.



SOUTHERN REGIONAL LOAD DESPATCH CENTRE

GENERATING UNITS OUTAGE STATUS IN SOUTHERN REGION

AS ON DATE

20-Nov-15

TIME 06:00 HRS

1 A. Generating Units Revived during Last 30 HRS (00:00 HRS of 19-Nov-15 to 06:00 HRS of 20-Nov-15)

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		REVIVAL		REASON OF OUTAGE
					DATE	TIME	DATE	TIME	
CENTRAL SECTOR									
1	TALCHER STG II	NTPC_TALST2	UNIT 6	500 MW	17-NOV-2015	18:21:00	19-NOV-2015	11:12:00	BOILER TUBE LEAKAGE
2									
3									
4									
5									
STATE SECTOR									
1	NCTPS ST2	TNEB	UNIT 2	600 MW	14-NOV-2015	19:28:00	19-NOV-2015	14:50:00	H/T DUE TO HIGH CHLORIDE
2	RAICHUR TPS	KPCL	UNIT 8	250 MW	19-NOV-2015	09:40:00	19-NOV-2015	21:02:00	AIR PREHEATER PROBLEM
3	RAYALASEEMA TPS	APGENCO	UNIT 1	210 MW	18-NOV-2015	02:25:00	19-NOV-2015	18:05:00	REASON AWAITED
4									
5									

1 B. Generating Units Under Planned Outage (Status at 06:00 HRS of 20-Nov-15)

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
CENTRAL SECTOR								
1	KUDANKULAM NPS	KKNPP	UNIT 1	1000 MW	24-JUN-2015	11:30:00	25-DEC-2015	ANNUAL MAINTENANCE
2	NEYVELI II	NLC	UNIT 2	210 MW	18-OCT-2015	00:04:00	26-NOV-2015	ANNUAL MAINTENANCE
3	NEYVELI II	NLC	UNIT 6	210 MW	25-OCT-2015	23:30:00	30-NOV-2015	ANNUAL MAINTENANCE
4	NEYVELI TS I EXP	NLC	UNIT 2	210 MW	05-NOV-2015	08:54:00	30-NOV-2015	ANNUAL MAINTENANCE
5								
STATE SECTOR								
1	KOTHAGUDAM TPS	TGGENCO	UNIT 4	60 MW	07-NOV-2015	01:12:00	07-DEC-2015	ANNUAL MAINTENANCE
2	KOTHAGUDAM TPS	TGGENCO	UNIT 5	120 MW	03-NOV-2015	09:25:00	30-NOV-2015	ANNUAL MAINTENANCE
3	NEYVELI I	TNEB	UNIT 7	100 MW	05-OCT-2015	11:35:00	20-NOV-2015	ANNUAL MAINTENANCE
4	RAICHUR TPS	KPCL	UNIT 6	210 MW	28-OCT-2015	01:02:00	20-NOV-2015	ANNUAL OVERHAULING
5	SIMHADRI TPS	NTPC_SIMH	UNIT 2	500 MW	15-NOV-2015	15:01:00	15-DEC-2015	ANNUAL MAINTENANCE
6	VIJAYAWADA TPS	APGENCO	UNIT 7	500 MW	10-NOV-2015	13:16:00	10-DEC-2015	ANNUAL MAINTENANCE

1 C. Generating Units Under Forced Outage (Status at 06:00 HRS of 20-Nov-15)

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
CENTRAL SECTOR								
1	NEYVELI TS II EXP	NLC	UNIT 2	250 MW	09-NOV-2015	13:25:00	20-NOV-2015	BOILER PROTECTION OPERATED
2	NTPL	NTPL	UNIT 2	500 MW	17-NOV-2015	16:24:00	22-NOV-2015	BREAKER PROBLEM SF6 GAS LEAKAGE
3	RAMAGUNDAM STPS	NTPC_RSTPS	UNIT 1	200 MW	12-NOV-2015	20:56:00	06-DEC-2015	BTL
4	RAMAGUNDAM STPS	NTPC_RSTPS	UNIT 7	500 MW	19-NOV-2015	10:56:00	22-NOV-2015	TRIPPED ON BTL
5	VALLUR	NTECL	UNIT 3	500 MW	09-NOV-2015	22:49:00	25-NOV-2015	H/T DUE TO COAL SHORTAGE
STATE SECTOR								
1	ENNORE TPS	TNEB	UNIT 1	60 MW	13-NOV-2015	20:44:00	24-NOV-2015	H/T DUE TO WET COAL
2	ENNORE TPS	TNEB	UNIT 2	60 MW	26-APR-2014	11:34:00	27-NOV-2015	CONDENSER TUBE LEAKAGE
3	ENNORE TPS	TNEB	UNIT 3	110 MW	09-JUN-2015	23:27:00	25-NOV-2015	GEN.PROTECTION OPERATED
4	ENNORE TPS	TNEB	UNIT 4	110 MW	09-NOV-2015	08:35:00	20-NOV-2015	FURNACE PRESSURE HIGH
5	IL&FS	IL&FS	UNIT 1	600 MW	08-NOV-2015	18:53:00	08-DEC-2015	H/T DUE TO NO SCH.
6	LANCO ST2	LANCO_LAN	UNIT 1	233 MW	18-OCT-2015	07:00:00	21-NOV-2015	H/T DUE TO NO GAS ALLOCATION
7	LANCO ST2	LANCO_LAN	UNIT 2	133 MW	18-OCT-2015	07:00:00	21-NOV-2015	H/T DUE TO NO GAS ALLOCATION
8	LANCO ST3A	LANCO_LAN	UNIT 2	133 MW	16-NOV-2015	13:25:00	26-NOV-2015	LUBE OIL SYSTEM PROBLEM
9	LANCO ST3B	LANCO_LAN	UNIT 1	233 MW	05-SEP-2015	12:31:00	21-NOV-2015	H/T AFTER COMPLETION OF TESTING WORKS
10	LANCO ST3B	LANCO_LAN	UNIT 2	133 MW	05-SEP-2015	12:31:00	21-NOV-2015	H/T AFTER COMPLETION OF TESTING WORKS
11	MEENAKSHI	MEPL	UNIT 1	150 MW	17-NOV-2015	06:59:00	24-NOV-2015	WATER WALL TUBE FAILURE
12	MEENAKSHI	MEPL	UNIT 2	150 MW	16-NOV-2015	09:23:00	23-NOV-2015	TRIPPED DUE TO COAL FEEDER JAMMING
13	NEYVELI I	TNEB	UNIT 2	50 MW	08-NOV-2015	13:40:00	26-NOV-2015	LIGNITE SHORTAGE
14	NEYVELI I	TNEB	UNIT 3	50 MW	09-NOV-2015	07:50:00	20-NOV-2015	H/T DUE TO WET COAL
15	NEYVELI I	TNEB	UNIT 4	50 MW	09-NOV-2015	06:40:00	21-NOV-2015	H/T DUE TO WET COAL
16	NEYVELI I	TNEB	UNIT 5	50 MW	08-NOV-2015	16:36:00	20-NOV-2015	LIGNITE SHORTAGE
17	NEYVELI I	TNEB	UNIT 9	100 MW	09-NOV-2015	19:56:00	20-NOV-2015	H/T DUE TO WET COAL
18	RAYALASEEMA TPS	APGENCO	UNIT 3	210 MW	19-NOV-2015	00:40:00	23-NOV-2015	REASON AWAITED
19	RAYALASEEMA TPS	APGENCO	UNIT 5	210 MW	19-NOV-2015	10:45:00	22-NOV-2015	ASH HANDLING PROBLEM
20	SDS TPS	APGENCO	UNIT 1	800 MW	12-NOV-2015	13:48:00	21-NOV-2015	BOILER MAINTAINANCE WORKS
21	SIMHAPURI	SEPL	UNIT 1	150 MW	18-NOV-2015	16:45:00	22-NOV-2015	BUNKER LEVEL LOW
22	SIMHAPURI	SEPL	UNIT 2	150 MW	16-NOV-2015	10:41:00	24-NOV-2015	TRIPPED DUE TO CYCLONE FLUE DUCT BELOW AREA REFRATORY FAILURE
23	SIMHAPURI	SEPL	UNIT 3	150 MW	18-NOV-2015	12:53:00	20-NOV-2015	H/T DUE TO FLOOD WATER ENTERED INTO CHP
24	SIMHAPURI	SEPL	UNIT 4	150 MW	18-NOV-2015	15:10:00	22-NOV-2015	BUNKER LEVEL LOW