

**POWER SYSTEM OPERATION CORPORATION LIMITED.**



**SOUTHERN REGIONAL LOAD DESPATCH CENTRE**

**GENERATING UNITS OUTAGE STATUS IN SOUTHERN REGION**

**AS ON DATE**

**07-Oct-15**

**TIME 06:00 HRS**

**1 A. Generating Units Revived during Last 30 HRS ( 00:00 HRS of 06-Oct-15 to 06:00 HRS of 07-Oct-15)**

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		REVIVAL		REASON OF OUTAGE
					DATE	TIME	DATE	TIME	
<b>CENTRAL SECTOR</b>									
1									
2									
3									
4									
5									
<b>STATE SECTOR</b>									
1	MEENAKSHI	MEPL	UNIT 2	150 MW	16-AUG-2015	00:03:00	06-OCT-2015	15:44:00	ANNUAL MAINTENANCE
2	METTUR TPS	TNEB	UNIT 4	210 MW	20-SEP-2015	01:07:00	07-OCT-2015	02:19:00	ANNUAL MAINTENANCE
3	RAICHUR TPS	KPCL	UNIT 6	210 MW	04-OCT-2015	11:22:00	06-OCT-2015	07:49:00	ECONOMISER PROBLEM
4	VIJAYAWADA TPS	APGENCO	UNIT 2	210 MW	05-OCT-2015	02:46:00	06-OCT-2015	12:37:00	ECONOMISER TUBE LEAKAGE
5	VIJAYAWADA TPS	APGENCO	UNIT 5	210 MW	06-OCT-2015	11:30:00	06-OCT-2015	12:20:00	FLAME FAILURE

**1 B. Generating Units Under Planned Outage ( Status at 06:00 HRS of 07-Oct-15)**

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
<b>CENTRAL SECTOR</b>								
1	KUDANKULAM NPS	KKNPP	UNIT 1	1000 MW	24-JUN-2015	11:30:00	30-OCT-2015	ANNUAL MAINTENANCE
2	NEYVELI II	NLC	UNIT 3	210 MW	15-SEP-2015	00:02:00	12-OCT-2015	ANNUAL MAINTENANCE
3	NEYVELI II	NLC	UNIT 5	210 MW	27-AUG-2015	00:05:00	10-OCT-2015	ANNUAL MAINTENANCE
4	RAMAGUNDAM STPS	NTPC_RSTPS	UNIT 4	500 MW	04-SEP-2015	00:30:00	14-OCT-2015	ANNUAL MAINTENANCE
5	VALLUR	NTECL	UNIT 1	500 MW	03-OCT-2015	00:08:00	12-OCT-2015	ANNUAL MAINTENANCE
<b>STATE SECTOR</b>								
1	BELLARY TPS	KPCL	UNIT 1	500 MW	07-AUG-2015	23:14:00	09-OCT-2015	ANNUAL MAINTENANCE
2	COSTEL ENERGEN	COSTAL	UNIT 1	600 MW	05-OCT-2015	03:54:00	08-OCT-2015	BOILER TUBE LEAKAGE
3	NEYVELI I	TNEB	UNIT 7	100 MW	05-OCT-2015	11:35:00	10-NOV-2015	ANNUAL MAINTENANCE
4								
5								

**1 C. Generating Units Under Forced Outage ( Status at 06:00 HRS of 07-Oct-15)**

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
<b>CENTRAL SECTOR</b>								
1	NEYVELI TS II EXP	NLC	UNIT 1	250 MW	15-SEP-2015	11:55:00	10-OCT-2015	BOILER TUBE LEAKAGE
2	NEYVELI TS II EXP	NLC	UNIT 2	250 MW	03-OCT-2015	08:01:00	09-OCT-2015	BOILER TUBE LEAKAGE
3	NTPL	NTPL	UNIT 1	500 MW	04-OCT-2015	07:35:00	10-OCT-2015	WATER VALVE TUBE LEAKAGE
4								
5								
<b>STATE SECTOR</b>								
1	ENNORE TPS	TNEB	UNIT 2	60 MW	26-APR-2014	11:34:00	31-OCT-2015	CONDENSER TUBE LEAKAGE
2	ENNORE TPS	TNEB	UNIT 3	110 MW	09-JUN-2015	23:27:00	20-OCT-2015	GEN.PROTECTION OPERATED
3	JINDAL	KPCL	UNIT 1	130 MW	02-OCT-2015	00:36:00	10-OCT-2015	TRIPPED DUE TO TURBINE BEARING VIBRATION HIGH
4	LANCO ST3A	LANCO_LAN	UNIT 1	233 MW	09-AUG-2015	13:00:00	08-OCT-2015	H/T FOR COD WORKS
5	LANCO ST3A	LANCO_LAN	UNIT 2	133 MW	09-AUG-2015	13:00:00	08-OCT-2015	H/T FOR COD WORKS
6	LANCO ST3B	LANCO_LAN	UNIT 1	233 MW	05-SEP-2015	12:31:00	07-OCT-2015	H/T AFTER COMPLETION OF TESTING WORKS
7	LANCO ST3B	LANCO_LAN	UNIT 2	133 MW	05-SEP-2015	12:31:00	07-OCT-2015	H/T AFTER COMPLETION OF TESTING WORKS
8	RAICHUR TPS	KPCL	UNIT 3	210 MW	23-MAY-2015	15:58:00	10-OCT-2015	GT FLASHOVER
9	SDS TPS	APGENCO	UNIT 2	800 MW	03-OCT-2015	22:35:00	10-OCT-2015	H/T DUE TO BOILER INSPECTION
10	UPCL	LANCO_UPCL	UNIT 2	600 MW	04-OCT-2015	00:30:00	13-OCT-2015	PRE-HEATER PROBLEM