

**POWER SYSTEM OPERATION CORPORATION LIMITED.**



**SOUTHERN REGIONAL LOAD DESPATCH CENTRE**

**GENERATING UNITS OUTAGE STATUS IN SOUTHERN REGION**

**AS ON DATE**

**31-Oct-15**

**TIME 06:00 HRS**

**1 A. Generating Units Revived during Last 30 HRS ( 00:00 HRS of 30-Oct-15 to 06:00 HRS of 31-Oct-15)**

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		REVIVAL		REASON OF OUTAGE
					DATE	TIME	DATE	TIME	
<b>CENTRAL SECTOR</b>									
1	KAIGA APS	KGS	UNIT 2	220 MW	20-OCT-2015	00:17:00	31-OCT-2015	01:38:00	ATTENDING PROCESS PROBLEMS
2									
3									
4									
5									
<b>STATE SECTOR</b>									
1									
2									
3									
4									
5									

**1 B. Generating Units Under Planned Outage ( Status at 06:00 HRS of 31-Oct-15)**

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
<b>CENTRAL SECTOR</b>								
1	KUDANKULAM NPS	KKNPP	UNIT 1	1000 MW	24-JUN-2015	11:30:00	03-NOV-2015	ANNUAL MAINTENANCE
2	NEYVELI II	NLC	UNIT 2	210 MW	18-OCT-2015	00:04:00	18-NOV-2015	ANNUAL MAINTENANCE
3	NEYVELI II	NLC	UNIT 6	210 MW	25-OCT-2015	23:30:00	30-NOV-2015	ANNUAL MAINTENANCE
4	NEYVELI TS I EXP	NLC	UNIT 1	210 MW	12-OCT-2015	12:40:00	12-NOV-2015	ANNUAL MAINTENANCE
5								
<b>STATE SECTOR</b>								
1	KOTHAGUDAM TPS	TGGENCO	UNIT 3	60 MW	28-OCT-2015	08:35:00	20-NOV-2015	ANNUAL MAINTENANCE
2	NEYVELI I	TNEB	UNIT 7	100 MW	05-OCT-2015	11:35:00	10-NOV-2015	ANNUAL MAINTENANCE
3	VIJAYAWADA TPS	APGENCO	UNIT 3	210 MW	28-OCT-2015	00:06:00	20-NOV-2015	ANNUAL MAINTENANCE
4								
5								

**1 C. Generating Units Under Forced Outage ( Status at 06:00 HRS of 31-Oct-15)**

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
<b>CENTRAL SECTOR</b>								
1	NEYVELI TS II EXP	NLC	UNIT 1	250 MW	15-SEP-2015	11:55:00	02-NOV-2015	BOILER TUBE LEAKAGE
2	NTPL	NTPL	UNIT 2	500 MW	31-OCT-2015	05:21:00	01-NOV-2015	FLAME FAILURE
3	VALLUR	NTECL	UNIT 3	500 MW	31-OCT-2015	01:16:00	02-NOV-2015	BOILER TUBE LEAKAGE
4								
5								
<b>STATE SECTOR</b>								
1	ENNORE TPS	TNEB	UNIT 2	60 MW	26-APR-2014	11:34:00	31-OCT-2015	CONDENSER TUBE LEAKAGE
2	ENNORE TPS	TNEB	UNIT 3	110 MW	09-JUN-2015	23:27:00	31-OCT-2015	GEN.PROTECTION OPERATED
3	LANCO ST2	LANCO_LAN	UNIT 1	233 MW	18-OCT-2015	07:00:00	02-NOV-2015	H/T DUE TO NO GAS ALLOCATION
4	LANCO ST2	LANCO_LAN	UNIT 2	133 MW	18-OCT-2015	07:00:00	03-NOV-2015	H/T DUE TO NO GAS ALLOCATION
5	LANCO ST3A	LANCO_LAN	UNIT 1	233 MW	09-AUG-2015	13:00:00	01-NOV-2015	H/T FOR COD WORKS
6	LANCO ST3A	LANCO_LAN	UNIT 2	133 MW	09-AUG-2015	13:00:00	03-NOV-2015	H/T FOR COD WORKS
7	LANCO ST3B	LANCO_LAN	UNIT 1	233 MW	05-SEP-2015	12:31:00	02-NOV-2015	H/T AFTER COMPLETION OF TESTING WORKS
8	LANCO ST3B	LANCO_LAN	UNIT 2	133 MW	05-SEP-2015	12:31:00	02-NOV-2015	H/T AFTER COMPLETION OF TESTING WORKS
9	RAICHUR TPS	KPCL	UNIT 3	210 MW	23-MAY-2015	15:58:00	15-NOV-2015	GT FLASHOVER
10	RAICHUR TPS	KPCL	UNIT 6	210 MW	28-OCT-2015	01:02:00	07-NOV-2015	ANNUAL OVERHAULING
11	RAICHUR TPS	KPCL	UNIT 7	210 MW	30-OCT-2015	21:31:00	01-NOV-2015	ECONOISER PROBLEM
12	RAYALASEEMA TPS	APGENCO	UNIT 1	210 MW	31-OCT-2015	03:30:00	31-OCT-2015	BUS BAR PROTECTION OPERATED
13	RAYALASEEMA TPS	APGENCO	UNIT 3	210 MW	31-OCT-2015	03:30:00	31-OCT-2015	BUS BAR PROTECTION OPERATED
14	RAYALASEEMA TPS	APGENCO	UNIT 5	210 MW	31-OCT-2015	01:24:00	01-NOV-2015	FURNACE SIDE PROBLEM
15	TPCIL	TPCIL	UNIT 2	660 MW	28-OCT-2015	01:44:00	01-NOV-2015	FOR ATTENDING THE MAIN STEAM DRAIN LINE LEAKAGE.