

POWER SYSTEM OPERATION CORPORATION LIMITED.



SOUTHERN REGIONAL LOAD DESPATCH CENTRE

GENERATING UNITS OUTAGE STATUS IN SOUTHERN REGION

AS ON DATE

05-Feb-16

TIME 06:00 HRS

1 A. Generating Units Revived during Last 30 HRS (00:00 HRS of 04-Feb-16 to 06:00 HRS of 05-Feb-16)

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		REVIVAL		REASON OF OUTAGE
					DATE	TIME	DATE	TIME	
CENTRAL SECTOR									
1									
2									
3									
4									
5									
STATE SECTOR									
1	NCTPS ST2	TNEB	UNIT 1	600 MW	03-FEB-2016	23:02:00	04-FEB-2016	05:14:00	PA FAN PROBLEM
2									
3									
4									
5									

1 B. Generating Units Under Planned Outage (Status at 06:00 HRS of 05-Feb-16)

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
CENTRAL SECTOR								
1								
2								
3								
4								
5								
STATE SECTOR								
1	KOTHAGUDAM TPS	TGGENCO	UNIT 7	120 MW	29-JAN-2016	02:03:00	16-FEB-2016	ANNUAL MAINTENANCE
2	RAICHUR TPS	KPCL	UNIT 1	210 MW	30-JAN-2016	00:24:00	07-MAR-2016	ANNUAL MAINTENANCE
3								
4								
5								

1 C. Generating Units Under Forced Outage (Status at 06:00 HRS of 05-Feb-16)

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
CENTRAL SECTOR								
1	KUDANKULAM NPS	KKNPP	UNIT 1	1000 MW	04-FEB-2016	22:34:00	07-FEB-2016	STEAM LEAK IN THE SECONDARY SIDE
2	NEYVELI TS II EXP	NLC	UNIT 1	250 MW	01-FEB-2016	01:24:00	06-FEB-2016	BOILER PROTECTION ACTED
3	NEYVELI TS II EXP	NLC	UNIT 2	250 MW	31-JAN-2016	17:18:00	06-FEB-2016	BOILER TUBE LEAK
4								
5								
STATE SECTOR								
1	COSTAL ENERGEN	COSTAL	UNIT 2	600 MW	04-FEB-2016	10:40:00		NO SCHEDULE
2	ENNORE TPS	TNEB	UNIT 1	60 MW	13-NOV-2015	20:44:00	01-APR-2016	H/T DUE TO WET COAL
3	ENNORE TPS	TNEB	UNIT 2	60 MW	26-APR-2014	11:34:00	01-APR-2016	CONDENSER TUBE LEAKAGE
4	ENNORE TPS	TNEB	UNIT 4	110 MW	12-JAN-2016	15:51:00	01-APR-2016	BFP CONTROL PANEL PROBLEM
5	KAKATIYA TPS	TGGENCO	UNIT 2	600 MW	02-FEB-2016	15:30:00	10-FEB-2016	GENERATOR PROTECTION ACTED
6	LANCO ST2	LANCO_LAN	UNIT 1	233 MW	11-JAN-2016	15:00:00	29-FEB-2016	NO GAS
7	LANCO ST2	LANCO_LAN	UNIT 2	133 MW	11-JAN-2016	15:00:00	29-FEB-2016	NO GAS
8	LANCO ST3A	LANCO_LAN	UNIT 1	233 MW	16-JAN-2016	05:00:00	29-FEB-2016	NON AVAILABILITY OF GAS
9	LANCO ST3A	LANCO_LAN	UNIT 2	133 MW	26-JAN-2016	04:54:00	29-FEB-2016	NON AVAILABILITY OF GAS
10	LANCO ST3B	LANCO_LAN	UNIT 1	233 MW	05-SEP-2015	12:31:00	29-FEB-2016	H/T AFTER COMPLETION OF TESTING WORKS
11	LANCO ST3B	LANCO_LAN	UNIT 2	133 MW	05-SEP-2015	12:31:00	29-FEB-2016	H/T AFTER COMPLETION OF TESTING WORKS
12	METTUR TPS	TNEB	UNIT 3	210 MW	01-FEB-2016	11:09:00	05-FEB-2016	KEPT STANDBY
13	NEYVELI I	TNEB	UNIT 9	100 MW	02-JAN-2016	08:08:00	29-FEB-2016	BEARING PROBLEM
14	RAICHUR TPS	KPCL	UNIT 2	210 MW	04-FEB-2016	22:54:00	06-FEB-2016	B T L
15	SIMHAPURI	SEPL	UNIT 1	150 MW	04-FEB-2016	18:54:00	05-FEB-2016	6.6KV CB PROBLEM
16	SIMHAPURI	SEPL	UNIT 3	150 MW	02-FEB-2016	07:42:00		LOW DEMAND
17	TUTUCORIN TPS	TNEB	UNIT 2	210 MW	04-FEB-2016	04:32:00	05-FEB-2016	KEPT STANDBY
18	TUTUCORIN TPS	TNEB	UNIT 3	210 MW	25-JAN-2016	03:18:00	20-FEB-2016	STATOR EARTH FAULT
19	VIJAYAWADA TPS	APGENCO	UNIT 7	500 MW	04-FEB-2016	22:47:00	07-FEB-2016	BOILER TUBE LEAKAGE