

POWER SYSTEM OPERATION CORPORATION LIMITED.



SOUTHERN REGIONAL LOAD DESPATCH CENTRE

GENERATING UNITS OUTAGE STATUS IN SOUTHERN REGION

AS ON DATE

17-Jan-16

TIME 06:00 HRS

1 A. Generating Units Revived during Last 30 HRS (00:00 HRS of 16-Jan-16 to 06:00 HRS of 17-Jan-16)

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		REVIVAL		REASON OF OUTAGE
					DATE	TIME	DATE	TIME	
CENTRAL SECTOR									
1	VALLUR	NTECL	UNIT 2	500 MW	06-JAN-2016	19:19:00	17-JAN-2016	05:00:00	B.T.L
2									
3									
4									
5									
STATE SECTOR									
1	MEENAKSHI	MEPL	UNIT 1	150 MW	16-JAN-2016	22:12:00	16-JAN-2016	23:57:00	TURBINE OIL LEAKAGE
2									
3									
4									
5									

1 B. Generating Units Under Planned Outage (Status at 06:00 HRS of 17-Jan-16)

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
CENTRAL SECTOR								
1	KUDANKULAM NPS	KKNPP	UNIT 1	1000 MW	24-JUN-2015	11:30:00	24-JAN-2016	ANNUAL MAINTENANCE
2								
3								
4								
5								
STATE SECTOR								
1	KAKATIYA TPS	TGGENCO	UNIT 1	500 MW	28-DEC-2015	13:17:00	15-FEB-2016	ANNUAL MAINTENANCE
2	KOTHAGUDAM TPS	TGGENCO	UNIT 9	250 MW	10-JAN-2016	16:10:00	21-JAN-2016	ANNUAL MAINTENANCE
3	RAICHUR TPS	KPCL	UNIT 2	210 MW	02-JAN-2016	23:46:00	28-JAN-2016	ANNUAL MAINTENANCE
4	SIMHAPURI	SEPL	UNIT 2	150 MW	17-JAN-2016	06:21:00		ANNUAL MAINTENANCE
5								

1 C. Generating Units Under Forced Outage (Status at 06:00 HRS of 17-Jan-16)

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
CENTRAL SECTOR								
1	MADRAS APS	MAPS	UNIT 2	220 MW	30-NOV-2015	23:12:00	23-JAN-2016	BI ANNUAL MAINTENANCE
2	NEYVELI TS II EXP	NLC	UNIT 2	250 MW	16-JAN-2016	18:56:00		TRIPPED DUE TO PA FAN PROBLEM
3	NTPL	NTPL	UNIT 2	500 MW	13-JAN-2016	23:30:00	20-JAN-2016	TRIPPED ON ELECTRIC FAULT
4								
5								
STATE SECTOR								
1	COSTAL ENERGEN	COSTAL	UNIT 1	600 MW	05-JAN-2016	17:12:00	20-JAN-2016	STEAM LEAK
2	COSTAL ENERGEN	COSTAL	UNIT 2	600 MW	15-JAN-2016	00:07:00	24-JAN-2016	H/T DUE TO NO SCH.
3	ENNORE TPS	TNEB	UNIT 1	60 MW	13-NOV-2015	20:44:00	24-JAN-2016	H/T DUE TO WET COAL
4	ENNORE TPS	TNEB	UNIT 2	60 MW	26-APR-2014	11:34:00	20-JAN-2016	CONDENSER TUBE LEAKAGE
5	ENNORE TPS	TNEB	UNIT 3	110 MW	13-JAN-2016	09:01:00	24-JAN-2016	H/T AS PER MERIT ORDER
6	ENNORE TPS	TNEB	UNIT 4	110 MW	12-JAN-2016	15:51:00	20-JAN-2016	BFP CONTROL PANEL PROBLEM
7	IL&FS	IL&FS	UNIT 1	600 MW	14-JAN-2016	22:29:00	18-JAN-2016	H/T DUE TO NO SCH.
8	KAKATIYA TPS	TGGENCO	UNIT 2	600 MW	14-JAN-2016	11:05:00	18-JAN-2016	FLAME FAILURE
9	LANCO ST2	LANCO_LAN	UNIT 1	233 MW	11-JAN-2016	15:00:00	20-JAN-2016	NO GAS
10	LANCO ST2	LANCO_LAN	UNIT 2	133 MW	11-JAN-2016	15:00:00	20-JAN-2016	NO GAS
11	LANCO ST3B	LANCO_LAN	UNIT 1	233 MW	05-SEP-2015	12:31:00	20-JAN-2016	H/T AFTER COMPLETION OF TESTING WORKS
12	LANCO ST3B	LANCO_LAN	UNIT 2	133 MW	05-SEP-2015	12:31:00	20-JAN-2016	H/T AFTER COMPLETION OF TESTING WORKS
13	NEYVELI I	TNEB	UNIT 9	100 MW	02-JAN-2016	08:08:00	20-JAN-2016	110 KV BUS BAR PROTECTION OPERATED
14	NORTH CHENNAI TPS	TNEB	UNIT 1	210 MW	14-JAN-2016	20:24:00	20-JAN-2016	B T L
15	SDS TPS	APGENCO	UNIT 1	800 MW	15-JAN-2016	13:30:00	20-JAN-2016	BOILER SIDE PROBLEM
16	TPCIL	TPCIL	UNIT 1	660 MW	16-JAN-2016	19:06:00		MAINTENANCE
17	TUTUCORIN TPS	TNEB	UNIT 2	210 MW	14-JAN-2016	22:55:00	18-JAN-2016	H/T DUE TO LOW DEMAND
18	TUTUCORIN TPS	TNEB	UNIT 3	210 MW	12-JAN-2016	02:30:00	18-JAN-2016	GENERATOR EARTH FAULT