

**POWER SYSTEM OPERATION CORPORATION LIMITED.**



**SOUTHERN REGIONAL LOAD DESPATCH CENTRE**

**GENERATING UNITS OUTAGE STATUS IN SOUTHERN REGION**

**AS ON DATE**

**25-Jan-16**

**TIME 06:00 HRS**

**1 A. Generating Units Revived during Last 30 HRS ( 00:00 HRS of 24-Jan-16 to 06:00 HRS of 25-Jan-16)**

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		REVIVAL		REASON OF OUTAGE
					DATE	TIME	DATE	TIME	
<b>CENTRAL SECTOR</b>									
1	NEYVELI TS II EXP	NLC	UNIT 2	250 MW	20-JAN-2016	04:59:00	24-JAN-2016	09:08:00	BOILER PROTECTION OPERATED
2	TALCHER STG II	NTPC_TALST2	UNIT 5	500 MW	23-JAN-2016	10:00:00	24-JAN-2016	13:10:00	BOILER TUBE LEAKAGE
3									
4									
5									
<b>STATE SECTOR</b>									
1	KAKATIYA TPS	TGGENCO	UNIT 1	500 MW	28-DEC-2015	13:17:00	24-JAN-2016	03:24:00	ANNUAL MAINTENANCE
2	RAICHUR TPS	KPCL	UNIT 7	210 MW	24-JAN-2016	03:20:00	24-JAN-2016	08:15:00	FD FAN PROBLEM
3	RAYALASEEMA TPS	APGENCO	UNIT 1	210 MW	23-JAN-2016	22:01:00	24-JAN-2016	19:31:00	B T L
4	TUTUCORIN TPS	TNEB	UNIT 5	210 MW	23-JAN-2016	22:41:00	25-JAN-2016	05:05:00	H/T DUE TO LESS DEMAND
5									

**1 B. Generating Units Under Planned Outage ( Status at 06:00 HRS of 25-Jan-16)**

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
<b>CENTRAL SECTOR</b>								
1	KUDANKULAM NPS	KKNPP	UNIT 1	1000 MW	24-JUN-2015	11:30:00	28-JAN-2016	ANNUAL MAINTENANCE
2								
3								
4								
5								
<b>STATE SECTOR</b>								
1	KOTHAGUDAM TPS	TGGENCO	UNIT 9	250 MW	10-JAN-2016	16:10:00	26-JAN-2016	ANNUAL MAINTENANCE
2	SIMHAPURI	SEPL	UNIT 2	150 MW	17-JAN-2016	06:21:00	26-JAN-2016	ANNUAL MAINTENANCE
3								
4								
5								

**1 C. Generating Units Under Forced Outage ( Status at 06:00 HRS of 25-Jan-16)**

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
<b>CENTRAL SECTOR</b>								
1	NEYVELI TS II EXP	NLC	UNIT 1	250 MW	21-JAN-2016	19:20:00	25-JAN-2016	BOILER PROTECTION
2	NTPL	NTPL	UNIT 2	500 MW	13-JAN-2016	23:30:00	28-JAN-2016	TRIPPED ON ELECTRIC FAULT
3								
4								
5								
<b>STATE SECTOR</b>								
1	COSTAL ENERGEN	COSTAL	UNIT 1	600 MW	05-JAN-2016	17:12:00	28-JAN-2016	STEAM LEAK
2	ENNORE TPS	TNEB	UNIT 1	60 MW	13-NOV-2015	20:44:00	27-JAN-2016	H/T DUE TO WET COAL
3	ENNORE TPS	TNEB	UNIT 2	60 MW	26-APR-2014	11:34:00	27-JAN-2016	CONDENSER TUBE LEAKAGE
4	ENNORE TPS	TNEB	UNIT 3	110 MW	13-JAN-2016	09:01:00	27-JAN-2016	H/T AS PER MERIT ORDER
5	ENNORE TPS	TNEB	UNIT 4	110 MW	12-JAN-2016	15:51:00	26-JAN-2016	BFP CONTROL PANEL PROBLEM
6	HNPCL	APGENCO	UNIT 1	525 MW	24-JAN-2016	19:47:00	26-JAN-2016	TURBINE LUBE OIL LINE LEAKAGE
7	IL&FS	IL&FS	UNIT 1	600 MW	22-JAN-2016	00:01:00	25-JAN-2016	H/T DUE TO NO SCHEDULE
8	KAKATIYA TPS	TGGENCO	UNIT 2	600 MW	14-JAN-2016	11:05:00	26-JAN-2016	FLAME FAILURE
9	LANCO ST2	LANCO_LAN	UNIT 1	233 MW	11-JAN-2016	15:00:00	28-JAN-2016	NO GAS
10	LANCO ST2	LANCO_LAN	UNIT 2	133 MW	11-JAN-2016	15:00:00	27-JAN-2016	NO GAS
11	LANCO ST3A	LANCO_LAN	UNIT 1	233 MW	16-JAN-2016	05:00:00	25-JAN-2016	NON AVAILABILITY OF GAS
12	LANCO ST3A	LANCO_LAN	UNIT 2	133 MW	16-JAN-2016	04:54:00	25-JAN-2016	NON AVAILABILITY OF GAS
13	LANCO ST3B	LANCO_LAN	UNIT 1	233 MW	05-SEP-2015	12:31:00	28-JAN-2016	H/T AFTER COMPLETION OF TESTING WORKS
14	LANCO ST3B	LANCO_LAN	UNIT 2	133 MW	05-SEP-2015	12:31:00	27-JAN-2016	H/T AFTER COMPLETION OF TESTING WORKS
15	METTUR TPS	TNEB	UNIT 4	210 MW	22-JAN-2016	23:48:00	25-JAN-2016	H/T DUE TO LESS DEMAND
16	NEYVELI I	TNEB	UNIT 2	50 MW	24-JAN-2016	02:58:00	27-JAN-2016	B T L
17	NEYVELI I	TNEB	UNIT 9	100 MW	02-JAN-2016	08:08:00	27-JAN-2016	110 KV BUS BAR PROTECTION OPERATED
18	NORTH CHENNAI TPS	TNEB	UNIT 2	210 MW	24-JAN-2016	02:56:00	27-JAN-2016	B T L
19	SDS TPS	APGENCO	UNIT 1	800 MW	15-JAN-2016	13:30:00	28-JAN-2016	BOILER SIDE PROBLEM
20	TUTUCORIN TPS	TNEB	UNIT 3	210 MW	25-JAN-2016	03:18:00	27-JAN-2016	STATOR EARTH FAULT