

POWER SYSTEM OPERATION CORPORATION LIMITED.



SOUTHERN REGIONAL LOAD DESPATCH CENTRE

GENERATING UNITS OUTAGE STATUS IN SOUTHERN REGION

AS ON DATE

28-Jan-16

TIME 06:00 HRS

1 A. Generating Units Revived during Last 30 HRS (00:00 HRS of 27-Jan-16 to 06:00 HRS of 28-Jan-16)

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		REVIVAL		REASON OF OUTAGE
					DATE	TIME	DATE	TIME	
CENTRAL SECTOR									
1	NTPL	NTPL	UNIT 2	500 MW	27-JAN-2016	21:17:00	27-JAN-2016	23:40:00	FLAME FAILURE
2									
3									
4									
5									
STATE SECTOR									
1	KOTHAGUDAM TPS	TGGENCO	UNIT 2	60 MW	27-JAN-2016	16:05:00	27-JAN-2016	17:43:00	TRIPPED ON FURNACE PRESSURE HIGH
2	METTUR TPS	TNEB	UNIT 4	210 MW	23-JAN-2016	23:48:00	27-JAN-2016	05:23:00	H/T DUE TO LESS DEMAND
3	NORTH CHENNAI TPS	TNEB	UNIT 2	210 MW	24-JAN-2016	02:56:00	27-JAN-2016	02:46:00	B T L
4									
5									

1 B. Generating Units Under Planned Outage (Status at 06:00 HRS of 28-Jan-16)

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
CENTRAL SECTOR								
1	KUDANKULAM NPS	KKNPP	UNIT 1	1000 MW	24-JUN-2015	11:30:00	31-JAN-2016	ANNUAL MAINTENANCE
2								
3								
4								
5								
STATE SECTOR								
1	KOTHAGUDAM TPS	TGGENCO	UNIT 9	250 MW	10-JAN-2016	16:10:00	03-FEB-2016	ANNUAL MAINTENANCE
2	SIMHAPURI	SEPL	UNIT 2	150 MW	17-JAN-2016	06:21:00	02-FEB-2016	ANNUAL MAINTENANCE
3								
4								
5								

1 C. Generating Units Under Forced Outage (Status at 06:00 HRS of 28-Jan-16)

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
CENTRAL SECTOR								
1	NEYVELI II	NLC	UNIT 2	210 MW	27-JAN-2016	11:00:00	31-JAN-2016	BOILER TUBE PUNCTURE
2	NEYVELI TS II EXP	NLC	UNIT 1	250 MW	30-JAN-2016	19:20:00	31-JAN-2016	BOILER PROTECTION
3	TALCHER STG II	NTPC_TALST2	UNIT 5	500 MW	27-JAN-2016	11:09:00	31-JAN-2016	BOILER TUBE LEAKAGE
4								
5								
STATE SECTOR								
1	HNPCL	APGENCO	UNIT 1	525 MW	24-JAN-2016	19:47:00	01-FEB-2016	TURBINE LUBE OIL LINE LEAKAGE
2	IL&FS	IL&FS	UNIT 1	600 MW	31-JAN-2016	00:01:00	31-JAN-2016	H/T DUE TO NO SCHEDULE
3	KAKATIYA TPS	TGGENCO	UNIT 2	600 MW	14-JAN-2016	11:05:00	01-FEB-2016	FLAME FAILURE
4	KOTHAGUDAM TPS	TGGENCO	UNIT 3	60 MW	27-JAN-2016	17:41:00	31-JAN-2016	BOILER TUBE LEAK
5	LANCO ST2	LANCO_LAN	UNIT 1	233 MW	11-JAN-2016	15:00:00	31-JAN-2016	NO GAS
6	LANCO ST2	LANCO_LAN	UNIT 2	133 MW	11-JAN-2016	15:00:00	31-JAN-2016	NO GAS
7	LANCO ST3A	LANCO_LAN	UNIT 1	233 MW	16-JAN-2016	05:00:00	31-JAN-2016	NON AVAILABILITY OF GAS
8	LANCO ST3A	LANCO_LAN	UNIT 2	133 MW	26-JAN-2016	04:54:00	31-JAN-2016	NON AVAILABILITY OF GAS
9	LANCO ST3B	LANCO_LAN	UNIT 1	233 MW	05-SEP-2015	12:31:00	31-JAN-2016	H/T AFTER COMPLETION OF TESTING WORKS
10	LANCO ST3B	LANCO_LAN	UNIT 2	133 MW	05-SEP-2015	12:31:00	31-JAN-2016	H/T AFTER COMPLETION OF TESTING WORKS
11	NEYVELI I	TNEB	UNIT 5	50 MW	25-JAN-2016	22:25:00	31-JAN-2016	CONDENSER LEAKAGE
12	NEYVELI I	TNEB	UNIT 9	100 MW	02-JAN-2016	08:08:00	31-JAN-2016	110 KV BUS BAR PROTECTION OPERATED
13	SDS TPS	APGENCO	UNIT 1	800 MW	15-JAN-2016	13:30:00	31-JAN-2016	BOILER SIDE PROBLEM
14	TUTUCORIN TPS	TNEB	UNIT 3	210 MW	25-JAN-2016	03:18:00	31-JAN-2016	STATOR EARTH FAULT
15	COSTAL ENERGEN	COSTAL	UNIT 1	600 MW	05-JAN-2016	17:12:00	31-JAN-2016	STEAM LEAK
16	ENNORE TPS	TNEB	UNIT 1	60 MW	13-NOV-2015	20:44:00	31-JAN-2016	H/T DUE TO WET COAL
17	ENNORE TPS	TNEB	UNIT 2	60 MW	26-APR-2014	11:34:00	31-JAN-2016	CONDENSER TUBE LEAKAGE
18	ENNORE TPS	TNEB	UNIT 4	110 MW	12-JAN-2016	15:51:00	31-JAN-2016	BFP CONTROL PANEL PROBLEM