

POWER SYSTEM OPERATION CORPORATION LIMITED.



SOUTHERN REGIONAL LOAD DESPATCH CENTRE

GENERATING UNITS OUTAGE STATUS IN SOUTHERN REGION

AS ON DATE

04-Apr-17

TIME 06:00 HRS

1 A. Generating Units Revived during Last 30 HRS (00:00 HRS of 03-Apr-17 to 06:00 HRS of 04-Apr-17)

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		REVIVAL		REASON OF OUTAGE
					DATE	TIME	DATE	TIME	
CENTRAL SECTOR									
1	SIMHADRI STGII	NTPC_SIMHST 2	UNIT 4	500	01-APR-2017	12:22:00	03-APR-2017	04:08:00	CONDENSER PROBLEM
2	VALLUR	NTECL	UNIT 2	500	31-MAR-2017	00:21:00	03-APR-2017	00:05:00	BOILER TUBE LEAKAGE
3									
4									
5									
STATE SECTOR									
1	NEYVELLI	TNEB	UNIT 1	50	02-APR-2017	17:30:00	04-APR-2017	02:27:00	BOILER TUBE LEAKAGE
2	YERMERS TPS	KPCL	UNIT 2	800	03-APR-2017	13:18:00	03-APR-2017	21:03:00	BOILER PREHEATER PROTECTION OPERATED
3									
4									
5									

1 B. Generating Units Under Planned Outage (Status at 06:00 HRS of 04-Apr-17)

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
CENTRAL SECTOR								
1	MADRAS APS	MAPS	UNIT 1	220	19-MAR-2017	15:58:00	27-APR-2017	ANNUAL MAINTENANCE
2	RAMAGUNDAM STPS	NTPC_RSTPS	UNIT 3	200	01-APR-2017	00:01:00	30-APR-2017	Overhauling work
3								
4								
5								
STATE SECTOR								
1	YERMERS TPS	KPCL	UNIT 1	800	08-MAR-2017	22:44:00		TRIPPED AFTER COD
2								
3								
4								
5								

1 C. Generating Units Under Forced Outage (Status at 06:00 HRS of 04-Apr-17)

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
CENTRAL SECTOR								
1	KUDANKULAM NPS	KKNPP	UNIT 2	1000	03-APR-2017	00:58:00		to rectify the passing of steam dump valves to condenser in secondary side.
2	KUDGI STPS	NTPC_KUDGI	UNIT 1	800	01-APR-2017	07:51:00		COAL FEEDING PROBLEM
3	KUDGI STPS	NTPC_KUDGI	UNIT 2	800	24-MAR-2017	07:50:00		H/T DURING TESTING
4	NTPL	NTPL	UNIT 2	500	02-APR-2017	16:35:00		SLAG REMOVAL WORKS
5	SIMHADRI STGII	NTPC_SIMHST 2	UNIT 3	500	31-MAR-2017	17:32:00		CONDENSER PROBLEM
STATE SECTOR								
1	BELLARY TPS	KPCL	UNIT 1	500	23-MAR-2017	11:19:00		WATER SHORTAGE
2	BELLARY TPS	KPCL	UNIT 3	700	07-JAN-2017	13:47:00		FLAME FAILURE
3	ENNORE TPS	TNEB	UNIT 1	60	25-NOV-2015	00:01:00		PROBLEM
4	ENNORE TPS	TNEB	UNIT 2	60	26-APR-2016	11:34:00		CONDENSER TUBE LEAKAGE
5	ENNORE TPS	TNEB	UNIT 3	110	14-NOV-2016	00:05:00		CONDENSER VACUUM LOW
6	ENNORE TPS	TNEB	UNIT 4	110	16-NOV-2016	20:31:00		H/T DUE TO HUNTING
7	HINDUJA	APGENCO	UNIT 2	520	30-MAR-2017	15:49:00		FUEL SHORTAGE
8	KAKATIYA TPS	TGGENCO	UNIT 2	500	02-APR-2017	11:44:00		BOILER TUBE LEAKAGE
9	KRISHNAPATTANAM	APGENCO	UNIT 2	800	01-APR-2017	19:20:00		BOILER TUBE LEAKAGE
10	LANCO ST3A	LANCO_LAN	UNIT 1	233	16-SEP-2016	05:40:00		NO GAS SUPPLY
11	LANCO ST3A	LANCO_LAN	UNIT 2	133	16-SEP-2016	05:39:00		NO GAS SUPPLY
12	LANCO ST3B	LANCO_LAN	UNIT 1	233	02-NOV-2016	00:01:00		NO SCHEDULE
13	LANCO ST3B	LANCO_LAN	UNIT 2	133	02-NOV-2016	00:01:00		NO SCHEDULE
14	RAYALASEEMA TPS	APGENCO	UNIT 5	210	03-APR-2017	09:29:00		BOILER TUBE LEAKAGE
15	SIMHAPURI	SEPL	UNIT 1	150	18-MAR-2017	00:08:00		LOW DEMAND
16	SIMHAPURI	SEPL	UNIT 2	150	27-DEC-2016	23:08:00		COOLING WATER PROBLEM
17	SIMHAPURI	SEPL	UNIT 3	150	24-DEC-2016	00:04:00		LOWER DEMAND
18	SINGRENI	TGGENCO	UNIT 2	600	02-APR-2017	04:51:00		BOILER TUBE LEAKAGE