

POWER SYSTEM OPERATION CORPORATION LIMITED.



SOUTHERN REGIONAL LOAD DESPATCH CENTRE

GENERATING UNITS OUTAGE STATUS IN SOUTHERN REGION

AS ON DATE

07-May-17

TIME 06:00 HRS

1 A. Generating Units Revived during Last 30 HRS (00:00 HRS of 06-May-17 to 06:00 HRS of 07-May-17)

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		REVIVAL		REASON OF OUTAGE
					DATE	TIME	DATE	TIME	
CENTRAL SECTOR									
1									
2									
3									
4									
5									
STATE SECTOR									
1	SINGRENI	TGGENCO	UNIT 1	600	02-MAY-2017	02:10:00	07-MAY-2017	03:18:00	BOILER TUBE LEAKAGE
2									
3									
4									
5									

1 B. Generating Units Under Planned Outage (Status at 06:00 HRS of 07-May-17)

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
CENTRAL SECTOR								
1	KUDANKULAM NPS	KKNPP	UNIT 1	1000	13-APR-2017	03:38:00		MAINTENANCE WORKS FOR 72 DAYS
2	MADRAS APS	MAPS	UNIT 1	220	19-MAR-2017	15:58:00	27-APR-2017	ANNUAL MAINTENANCE
3								
4								
5								
STATE SECTOR								
1	YERMERS TPS	KPCL	UNIT 1	800	08-MAR-2017	22:44:00		TRIPPED AFTER COD
2								
3								
4								
5								

1 C. Generating Units Under Forced Outage (Status at 06:00 HRS of 07-May-17)

S No.	STATION	AGENCY	UNITNO	CAPACITY	OUTAGE		EXPECTED DATE	REASON OF OUTAGE
					DATE	TIME		
CENTRAL SECTOR								
1	KUDANKULAM NPS	KKNPP	UNIT 2	1000	04-MAY-2017	03:43:00		SG LEVEL LOW
2	KUDGI STPS	NTPC_KUDGI	UNIT 1	800	19-APR-2017	22:53:00		PA FAN PROBLEM
3	KUDGI STPS	NTPC_KUDGI	UNIT 2	800	24-MAR-2017	07:50:00		H/T DURING TESTING
4	NEYVELI II	NLC	UNIT 5	210	05-MAY-2017	13:27:00		WATER WALL TUBE LEAKAGE
5	NEYVELI TS II EXP	NLC	UNIT 1	250	06-MAY-2017	04:55:00		ECONOMISER TUBE LEAKAGE
6	RAMAGUNDAM STPS	NTPC_RSTPS	UNIT 3	200	02-MAY-2017	09:54:00		BOILER TUBE LEAKAGE
STATE SECTOR								
1	BELLARY TPS	KPCL	UNIT 1	500	23-MAR-2017	11:19:00		WATER SHORTAGE
2	BELLARY TPS	KPCL	UNIT 3	700	07-JAN-2017	13:47:00		FLAME FAILURE
3	COSTEL ENERGEN	COSTAL	UNIT 1	600	14-APR-2017	06:25:00		H/T DUE TO LOW COAL STOCK
4	ENNORE TPS	TNEB	UNIT 1	60	25-NOV-2015	00:01:00		PROBLEM
5	ENNORE TPS	TNEB	UNIT 2	60	26-APR-2016	11:34:00		CONDENSER TUBE LEAKAGE
6	ENNORE TPS	TNEB	UNIT 3	110	14-NOV-2016	00:05:00		CONDENSER VACUUM LOW
7	ENNORE TPS	TNEB	UNIT 4	110	16-NOV-2016	20:31:00		H/T DUE TO HUNTING
8	HINDUJA	APGENCO	UNIT 2	520	16-APR-2017	20:48:00		TRIPPED ON electrical fault
9	JINDAL	KPCL	UNIT 5	300	23-APR-2017	0		WATER LEVEL SHORTAGE
10	LANCO ST3A	LANCO_LAN	UNIT 1	233	16-SEP-2016	05:40:00		NO GAS SUPPLY
11	LANCO ST3A	LANCO_LAN	UNIT 2	133	16-SEP-2016	05:39:00		NO GAS SUPPLY
12	LANCO ST3B	LANCO_LAN	UNIT 1	233	02-NOV-2016	00:01:00		NO SCHEDULE
13	LANCO ST3B	LANCO_LAN	UNIT 2	133	02-NOV-2016	00:01:00		NO SCHEDULE
14	MEENAKSHI	MEPL	UNIT 1	150	25-APR-2017	00:08:00		LOW demand
15	RAICHUR TPS	KPCL	UNIT 2	210	06-MAY-2017	01:37:00		FOR ATTENDING HYDROGEN GAS LEAKAGE
16	SIMHAPURI	SEPL	UNIT 1	150	18-MAR-2017	00:08:00		LOW DEMAND
17	SIMHAPURI	SEPL	UNIT 2	150	27-DEC-2016	23:08:00		COOLING WATER PROBLEM
18	SIMHAPURI	SEPL	UNIT 3	150	10-APR-2017	08:48:00		Common intake pipe leakage
19	SIMHAPURI	SEPL	UNIT 4	150	07-APR-2017	05:25:00		ID FAN PROBLEM
20	UPCL	LANCO_UPCL	UNIT 1	600	05-MAY-2017	08:21:00		TRIPPED DUE TO COOLING WATER PROBLEM
21	YERMERS TPS	KPCL	UNIT 2	800	07-APR-2017	20:07:00		BUNKER PROBLEM